

GUJARAT POLLUTION CONTROL BOARD

Head Office, "Paryavaran Bhavan"

Sector 10-A, Gandhinagar - 382010

CIRCULAR

Sub: Control of Emissions from in-use DG Sets by installing Retrofitted Emission Control Device (RECD) or shifting to gas based generator in the non-attainment cities in Gujarat.

Whereas, the Government of India has launched the National Clean Air Programme (NCAP) in 2019 for reduction of ambient air pollution, wherein emissions from diesel generator (DG) sets have been identified as one of the major sources of air pollution in Indian cities and States;

Whereas, Hon'ble National Green Tribunal (NGT) vide order dated 06.08.2019 in O.A. 681/2018(PB) has directed that emissions from in-use DG Sets shall be effectively controlled through suitable emission reduction measures including retrofitting of emission control devices;

Whereas, the Central Pollution Control Board (CPCB) has notified procedures for certification and testing of Retrofit Emission Control Devices (RECDs) on 28.03.2023 and has advised all State Pollution Control Boards (SPCBs) to implement appropriate emission control measures for in-use DG Sets;

Whereas, the Gujarat Pollution Control Board (GPCB) had earlier issued Circular No. GPCB/Air Action Plan-09/757115 dated 26.10.2023 directing all industries and establishments operating DG Sets of capacity 125 KVA and above in the State of Gujarat to comply with emission control requirements.

Whereas, the Commission for Air Quality Management (CAQM) has issued direction No. 76 dated 29.09.2023 as amended on 22.02.2024, prescribing regulated operation of DG Sets by adoption of RECDs and cleaner technologies in the entire NCR, by adopting appropriate emission control measures such as retrofitting Emission Control Devices (ECDs)/dual fuel systems/shifting to gensets compliant to GSR 804(E) for D. G. Sets, etc. as stipulated therein.

Whereas, the CPCB has recommended vide its letter dated 22.03.2024 that SPCBs/PCCs may also consider taking similar measures for control of ambient air pollution from DG Set emissions in non-attainment cities, such as (i) use of certified RECDs from approved manufacturers for in-use DG Sets and (ii) adoption of any suitable Air Pollution Control Device (APCD) for DG Sets of more than 800 KW, strictly subject to compliance of emission standards;

In light of above and in continuation of the GPCB's circular dated 26.10.2023, all industrial, commercial, residential and office establishments, etc., operating DG Sets in the non-attainment cities in Gujarat are hereby directed to comply with the recommendations of the CPCB's letters dated 22.03.2024 for implementation of the CAQM's direction No. 76 dated 29.09.2023 as amended on 22.02.2024 (copies enclosed).

(Dipali Tank)
Member Secretary

Encl: As above.

No: GPCB/PUR/e-file/128/2026/0390/Legal/3/2026

Date: as per E-sign

To,

All industrial, commercial, residential and office establishments, etc. operating DG Sets in the non-attainment cities in Gujarat.

[Promulgated through display on the website of the GPCB]

Signature Not Verified

Signed by: DIPALI ALPESH TANK
Member Secretary
Date: 2026.07.07
17:17:19 +5:30

File No: GPCB/PUR/e-file/128/2026/0390/Legal

Approved By: Chairman, Chairman Office, GPCB

Open the document in Adobe Acrobat DC to verify the E-sign



**COMMISSION FOR AIR QUALITY MANAGEMENT
IN NATIONAL CAPITAL REGION AND ADJOINING AREAS**

17th Floor, Jawahar Vyapar Bhawan (STC Building)
Tolstoy Marg, New Delhi-110001

F. No. A-11018/01/ 2021-CAQM//5322-15331 Dated: 29.09.2023

Subject: Directions under Section 12 of the Commission for Air Quality Management in National Capital Region and Adjoining Areas Act, 2021 – Review of regulations for use of DG sets in NCR.

WHEREAS, Ministry of Environment, Forest and Climate Change, Government of India, in exercise of the powers conferred under Section 3 of the Commission for Air Quality Management in National Capital Region and Adjoining Areas Act 2021, has constituted the Commission for Air Quality Management in National Capital Region and Adjoining Areas (hereinafter referred to as the Commission);

WHEREAS, under Section 12 (1) of the Act, the Commission is vested with powers to take all such measures, issue directions, etc., as it deems necessary or expedient for the purpose of protecting and improving the quality of the air in the National Capital Region and Adjoining Areas;

WHEREAS, Section 12 (2) (ix) of the Act empowers the Commission to issue directions in writing to any person, officer, or any authority and such person, officer or authority shall be bound to comply with such directions;

WHEREAS, Section 12(2)(iv) of the Act empowers the Commission to lay down parameters for discharge of emissions from various sources whatsoever that have implications on the air quality in the region;

3rd

WHEREAS, Section 12(2)(v) of the Act also empowers the Commission to impose restrictions and regulate operations or processes that have implications on air quality in the region;

WHEREAS, the Commission has repeatedly taken up the matter relating to air pollution with the State governments of Haryana, Rajasthan, Punjab, Uttar Pradesh and Government of NCT of Delhi and various organizations concerned of the Central and State Governments/ GNCTD and has issued various Directions, Advisories and Orders for effective implementation of measures for abating air pollution in NCR, from time to time;

WHEREAS, the Commission has observed and has been sensitizing all stakeholders that, amongst others, large-scale unregulated use of Diesel Generator (DG) sets is a major contributing factor for deterioration of air quality in the region;

WHEREAS, in wake of generally prevailing adverse air quality in NCR during the winter season, the Commission, through directions No. 54-57 dated 08.02.2022, followed by Direction No. 68 dated 14.09.2022 and its related orders called for regulated use of DG Sets in the NCR, particularly during the periods of restrictions under the GRAP, subject to adopting emission control measures /devices/ systems such as retrofitted Emission control devices (ECDs) and dual fuel mode (gas and diesel), amongst other means of emission control;

WHEREAS, large number of DG sets operating in the region, even during the periods other than restrictions under the GRAP, cause heavy air pollution and are a matter of concern and thus, with a view to regulating the use of DG Sets even for such periods, the Commission issued Direction No. 71 for expeditious conversion of DG Sets to dual fuel mode, in areas where gas infrastructure and supply is available;

WHEREAS, the Commission from time to time reviewed the progress and status in this matter, in line with various directions issued by it;

3rd

WHEREAS, the Commission revisited / reviewed some provisions of the extant directions on the regulated use of DG sets and issued a revised Direction No. 73 dated 02.06.2023, to be applicable across all sectors in the NCR including Industrial, Commercial, Residential and Office establishments etc., as well as permitting more time to implement the schedule w.e.f. 01.10.2023.

WHEREAS, preparatory actions were initiated by various stakeholders towards emission control from DG sets through retro-fitted ECDs and / or dual fuel systems, a number of representations were still being made to the Commission, including deliberations / meetings with various stakeholders in this context, wherein the following were highlighted:

- i. Issues related to availability of certified RECDs and agencies for all capacity ranges and vintages of DG sets.
- ii. Issues related to availability / delays in PNG infrastructure and supply, purely for DG sets.
- iii. Techno-commercial issues, logistics and time involved for fitment of RECDs / conversion to dual fuel mode.
- iv. Issues related to availability of DG sets to the latest standards as in MoEFCC notification No. GSR 804(E) dated 03.11.2022 (CPCB-IV).
- v. No means for emission control in under 19 kW capacity range of DG sets (neither RECDs nor dual fuel mode are available / suited).
- vi. Issues related to use of DG sets for emergency services.

Owing to the above, a number of stakeholders broadly requested for the following:

- (a) Extension of the deadline of 30.09.2023, as laid down in Direction No. 73, by about 3 months.
- (b) Stipulating a condition of '**OR**' instead of '**AND**' towards fitment of RECDs and conversion to dual fuel system, for all categories of DG sets above 19kW capacity.
- (c) Permitting DG Sets of >800 kW capacity to be run uninterruptedly for the durations of power supply failure, subject to compliance of

2amp

standards as in Direction No. 73 dated 02.06.2023, even during restrictions under GRAP.

- (d) Permitting such DG sets of < 125 kW capacity to be run for emergency services, even during the restrictions under the GRAP, where either certified ECDs are presently not available at all or where gas infrastructure and supply is also not available to enable running them in a dual fuel mode.

NOW, THEREFORE, in due consideration of the contentions and submissions made by various stakeholders, issues in ground level implementation, availability of RECDs / dual fuel systems / new gensets to CPCB -IV standards and various other techno-commercial considerations put forth by them, the Commission, pursuant to a comprehensive review and in supersession of all extant directions / orders / guidelines on the regulations for DG sets, now directs for adoption of the following Schedule for regulated operations of DG sets (only as a backup against regular power supply failures) across all sectors in NCR including Industrial, Commercial, Residential and Office establishments etc.:

S. No.	Capacity Range of DG sets	System to be adopted for control of emissions	Regulations for use
1.	Power generating sets of all capacities running on LPG/ Natural Gas/ Bio-gas/Propane/Butane	None	No restrictions (Even during periods under GRAP)
2.	Power generating sets of all capacities up to 800 kW to standards as per MoEFCC notification No. GSR 804(E) dated 03.11.2022	None	No restrictions. (Even during periods under GRAP)

2/2/23

3.	800 kW and above	Any emission control mechanism, strictly subject to compliance of emission standards as indicated below. *	No restrictions (Even during periods under GRAP)
4.	125 kW to less than 800 kW	Dual fuel mode OR Retro-fitted ECDs through certified vendors / agencies	No restrictions (Even during periods under GRAP)
5.	19 kW to less than 125 kW	Dual fuel mode	No restrictions (Even during periods under GRAP) DG Sets not working in a dual fuel mode, only owing to non-availability of gas infrastructure and supply, shall be permitted only for emergency services as stipulated in this direction.
6.	Portable DG sets (below 19 kW)	Presently no specific means of emission control are available in this category / capacity range of DG sets.	No restrictions during the periods, other than restrictions under GRAP. Not to be generally permitted during periods of restriction under GRAP. These shall, however, be permitted even during periods under GRAP only for emergency services as stipulated in this direction.

2014

***Standards for stack emissions for 800 kW and above capacity DG sets**

S.No	Parameter	Emission Standards
i.	PM (at 15% O ₂)	50 mg / Nm ³
ii.	NOx (at 15% O ₂)	650 mg / Nm ³
iii.	CO (at 15% O ₂)	100 mg / Nm ³
iv.	Minimum DG Stack height	30 meters OR minimum 6 meters above the height of the building where DG set is installed, whichever is higher. For example , if the building height where such DG set is installed is 20 meters, minimum stack height for DG set should be 30 meters from ground level; While, if the building height itself is 27 meters, the minimum stack height for the DG set should be 33 meters from the ground level.

The regulated schedule for operation of DG sets issued vide Direction No. 73 dated 02.06.2023 comes to effect from 01.10.2023. The revised schedule as above further eases out the means of implementation and addresses practical difficulties and techno-commercial concerns of various stakeholders and thus the revised schedule for regulation of DG sets would be in force in the entire NCR w.e.f. 01.10.2023.

Notwithstanding the revised schedule as above, in the interest of not disrupting emergency services and permitting sufficient time for adopting the stipulated emission control mechanism in such existing DG Sets, the Commission, hereby, as a one-time exception, permits DG Sets for all capacity ranges (which have still not been equipped with emission control devices / systems as per the above noted schedule), to be run only for emergency services in the NCR as listed below, even under periods of restrictions under the GRAP, **only up to 31.12.2023** and strictly subject to adherence to the above noted schedule / measures for emission control thereafter:

- (i) Elevators / Escalators / Travelators etc. in various installations; Commercial entities / residential societies shall, however, ensure that operation of DG sets and supply

2nd

therefrom is purely limited to operation of elevators / escalators / travelators etc. and not for any other activities of commercial entities / residential societies.

- (ii) Medical Services (Hospital/Nursing Home/Health care facilities) including units involved in manufacturing of life saving medical equipment/devices, drugs and medicines.
- (iii) Railway Services / Railway Stations.
- (iv) Metro Rail Corporation & MRTS Services, including trains and stations.
- (v) Airports and Inter-State Bus Terminals (ISBTs).
- (vi) Sewage Treatment Plants.
- (vii) Water pumping Stations.
- (viii) Projects related to national security, defence & of national importance.
- (ix) Telecommunications and IT/ data services.

It is further reiterated that appropriate emission control mechanism shall be put in place on or before 31.12.2023, in respect of DG sets being used in above listed emergency services, to avoid action under the relevant provisions of laws / rules / regulations / directions etc., thereafter.

NCR State PCBs/ DPCC shall ensure compliance of above noted directions and regularly monitor the field level implementation.

— sd —
(Arvind Nautiyal)
Member- Secretary

To

1. The Chief Secretary, Government of NCT of Delhi
2. The Chief Secretary, Government of Haryana
3. The Chief Secretary, Government of Rajasthan
4. The Chief Secretary, Government of Uttar Pradesh


Copy to:

1. Chairman, DPCC
2. Chairman, HSPCB
3. Chairman, RSPCB
4. Chairman, UPPCB
5. Chairman, CPCB.
6. The Chairperson and all Members, CAQM.

— sd —
(Arvind Nautiyal)
Member- Secretary



राष्ट्रीय राजधानी क्षेत्र और निकटवर्ती क्षेत्र
वायु गुणवत्ता प्रबंधन आयोग
Commission for Air Quality Management in
National Capital Region and
Adjoining Areas



F. No.11016/01/ 2022-CAQM.Vol-III

Dated: 22.02.2024

Subject: Amendments to Direction No. 76 dated 29.09.2023- Regulated use of DG Sets-reg

Pursuant to a comprehensive review and in supersession of all extant directions / orders / guidelines on the regulations for DG sets, Direction No. 76 dated 29.09.2023 was issued by the Commission under section 12 of the Commission for Air Quality Management in NCR & Adjoining Area, Act, 2021, directing for adoption of the Schedule for regulated operations of DG sets (only as a backup against regular power supply failures) across all sectors in NCR including Industrial, Commercial, Residential and Office establishments etc.

2. As certified Retrofitted Emission Control Devices (RECD) are now also available for 61 to 125 KW capacity range of DG sets, Sr. No 4 & 5 in said Direction No. 76 dated 29.09.2023 are hereby amended as under:

S. No.	DG set Capacity range as mentioned in Direction No. 76	DG Set Capacity range as amended now
4.	125 KW to less than 800 KW	61 KW to less than 800 KW
5.	19 KW to less than 125 KW	19 KW to less than 61 KW

3. All other stipulations under the Direction No 76 dated 29.09.2023 will remain unaltered.

(Arvind Nautiyal)

To,

1. The Chief Secretary, Government of NCT of Delhi
2. The Chief Secretary, Government of Haryana
3. The Chief Secretary, Government of Rajasthan
4. The Chief Secretary, Government of Uttar Pradesh

Copy to:

1. Chairman, DPCC
2. Chairman, HSPCB
3. Chairman, RSPCB
4. Chairman, UPPCB
5. Chairman, CPCB.
6. The Chairperson and all Members, CAQM

(Arvind Nautiyal)
Member-Secretary

17 वी मंजिल, जवाहर व्यापार भवन (एस. टी.सी. बिल्डिंग), टॉलस्टॉय मार्ग, नई दिल्ली-110001

दूरभाष : 011-23701213, ई-मेल : caqm-ncr@gov.in

17th Floor, Jawahar Vyapar Bhawan (STC Building), Tolstoy Marg, New Delhi-110001

Tel:011-23701213, E-mail: caqm-ncr@gov.in



-2573-

केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय, भारत सरकार
MINISTRY OF ENVIRONMENT, FOREST & CLIMATE CHANGE, GOVT. OF INDIA

SPEED POST / EMAIL

F.No.: EQ-11099/8/2021-AQM-HO-CPCB-HO-Part(5)

22.03.2024

To,
The Member Secretary
State Pollution Control Boards/ Committees
(As per the list)

Sub.: Control of Emissions from in-use DG sets by installing Retrofitted Emission Control Device (RECD) or shifting to gas based generator- reg.

Sir,

Government of India has launched National Clean Air Programme (NCAP) in 2019 as a National level strategy to reduce air pollution levels across the country. NCAP is being implemented in 131 non-attainment cities with the aim for reduction of particulate matter concentration by 40% by the year 2025-26. As per NCAP document, overall contribution of DG Sets to the ambient air pollution in non-attainment cities is 7-18%.

NCAP document also outlines the States/UTs to ensure use of Retrofitted Emission Control Device (RECD) having a minimum specified PM capturing efficiency of at least 70%, type approved by one of the 5 CPCB recognized labs; or shifting to gas-based generators by employing new gas-based generators or retrofitting the existing DG sets for partial gas usage.

Further, for control of emissions from the DG sets in National Capital Region (NCR), the Commission for Air Quality Management (CAQM) has issued statutory direction No.76, dated 29.09.2023 (as amended) for regulating operation of DG sets across all sectors namely industrial, commercial, residential, offices etc. in the entire NCR, by adopting appropriate measures such as retrofitting Emission Control Devices (ECDs)/ dual fuel systems/shifting to gensets compliant to GSR 804(E) for DG sets, etc as stipulated therein. A copy of the said direction is attached for ready reference.

In view of the above, SPCB/PCCs may also consider taking such measures for control of ambient air pollution from DG sets emission in non -attainment cities such as:

1. Use of certified RECDs from approved manufacturers for in-use DG sets of 61 KW to 800 KW capacity, which are older than five years from date of manufacturing and upto its useful life (i.e. 15 years from the date of manufacturing or 50,000 hours of operation, whichever is earlier) or use of Dual fuel system for in-use DG sets of less than 800 KW capacity upto its useful life as mentioned above or shifting to gensets meeting emission norms as per GSR 804(E) dated 3.11.22.
2. Adopt any suitable Air Pollution Control Device (APCD), strictly subject to compliance of emission standards notified vide GSR 489 (E) dated 09.07.2002 for DG sets of more than 800 KW.

Yours faithfully,

(Bharat Kumar Sharma)
Member Secretary

Encl.: As above

550

‘परिवेश भवन’ पूर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, New Delhi - 110032

दूरभाष/Tel: 43102030, 22305792, वेबसाइट/Website : www.cpcb.nic.in

List

1. The Member Secretary Andhra Pradesh State Pollution Control Board D. No.33-26-14 D/2, Near Sunrise Hospital, Pushpa Hotel Centre, Chalmvari Street, Kasturibaipet, Vijayavada-520010	2. The Member Secretary Chhattisgarh Environment Conservation Board Paryavas Bhawan, Block Sector-19 Naya Raipur, Chhattisgarh- 492099
3. The Member Secretary Assam State Pollution Control Board Bamunimaidan, Guwahati, Assam-781021	4. The Member Secretary Bihar State Pollution Control Board Parivesh Bhawan, Plot No.N-B/2, Patliputra Industrial Area, Patna-800023
5. The Member Secretary Gujarat State Pollution Control Board Sector 10-A, Gandhi Nagar – 382043, Gujarat	6. The Member Secretary Haryana State Pollution Control Board C-11, Sector 6, Panchkula, Haryana-134109
7. The Member Secretary H. P. State Pollution Control Board Paryavaran Bhavan, Phase III, New Shimla – 171009 Himachal Pradesh	8. The Member Secretary J&K State Pollution Control Board, Parivesh Bhawan, Forest Complex, Gladni, Narwal, transport Nagar, Jammu (J&K)
9. The Member Secretary Jharkhand State Pollution Control Board T.A Building, HEC Campus, P.O. Dhurwa Ranchi, Jharkhand – 834004	10. The Member Secretary Karnataka State Pollution Control Board Parisara Bhavan, 4 th & 5 th floors Church Street, Bangalore – 560 001, Karnataka
11. The Member Secretary Maharashtra State Pollution Control Board Kalpataru Point, 3 rd & 4 th floors Sion Matunga Scheme Road No. 6 Opp. Cine Planet, Sion Circle, Sion (E), Mumbai-400 022, Maharashtra	12. The Member Secretary M. P. State Pollution Control Board Paryavaran Parisar, E-5 Arera Colony Bhopal – 462016, Madhya Pradesh
13. The Member Secretary Meghalaya State Pollution Control Board Arden, Lumpyngngad, Shillong – 793014, Meghalaya	14. The Member Secretary Tamil Nadu State Pollution Control Board No. 76, Mount Salai, Guindy, Chennai – 600032, Tamil Nadu
15. The Member Secretary Nagaland State Pollution Control Board Signal Point, Dimapur, Nagaland – 797112	16. The Member Secretary Odisha State Pollution Control Board Paribesh Bhawan, A-118, Nilakanta Nagar, Unit –VIII, Bhubaneshwar – 751012, Odisha
17. The Member Secretary Punjab State Pollution Control Board Nabha Road, ITI Rd, Adarsh Nagar, Prem Nagar, Patiala – 147001, Punjab	18. The Member Secretary Rajasthan State Pollution Control Board A-4 Institutional Area, Jhalane Dungri Jaipur – 302004, Rajasthan
19. The Member Secretary Telangana State Pollution Control Board Paryavaran Bhavan A-3, Industrial Estate, Sanath Nagar, Hyderabad – 500 018, Telangana	20. The Member Secretary Chandigarh Pollution Control Committee Paryavaran Bhawan Madhya Marg, Sector - 19 B, Chandigarh – 160019.

21. The Member Secretary Uttarakhand Pollution Control Board 29/20, Nemi Road, Dehradun Uttarakhand- 248001	22. The Member Secretary Delhi Pollution Control Committee 4 th floor, ISBT Building, Kashmeri Gate, Delhi - 110006.
23. The Member Secretary West Bengal State Pollution Control Board Paribesh Bhavan Building, No.10-A Block -LA, Sector 3, Salt Lake City, Kolkata - 700 091, West Bengal	24. The Member Secretary Uttar Pradesh Pollution Control Board Building.No. TC-12V Vibhuti Khand, Gomti Nagar Lucknow-226 010